



**CITY OF CATHEDRAL CITY  
SWIMMING POOL DRAINAGE PERMIT**

LOCATION OF POOL:			
PERMITTEE:		PHONE NO.	
EMAIL:		DATE OF POOL DRAIN:	
DISPOSAL OF WATER, STREET NAME:		OTHER:	
<p align="center"><b>CONDITION OF PERMIT</b></p> <p>1) Drainage shall be permitted between 7:00 p.m. and 7:00 a.m., Monday through Thursday.</p> <p>2) Pool water require the pool owner/operator to stop chlorinating the pool for <u>three to seven days</u>, and to test the dechlorinated water for confirmation of an acceptable level of total chlorine residual (0.1mg/L) in the water prior to discharge or drainage.</p> <p>All the following criteria are to meet:</p> <ul style="list-style-type: none"> <li>- Total Residual Chlorine does not exceed 0.1 mg/L (parts per million)</li> <li>- The pH is between 6.5 and 8.5</li> <li>- By visual observation the water is free of filter media, vegetative debris, and other materials.</li> </ul> <p>3) The permit holder shall be responsible for providing barricades and/or warning device if necessary to protect the public from injury or damages occasioned by the permit equipment or apparatus</p> <p>4) It is the responsibility of the permitholder to make sure the flow of water into streets does not create interference, a traffic safety hazard, or a nuisance to others.</p> <p>5) The permit holder shall also be responsible for damages to public or private party occasioned by the pool drainage.</p> <p>6) The permit holder shall post one copy of this permit at the site and in a location accessible to view of the public.</p> <p>7) The creation of a nuisance shall be cause for revocation of this permit.</p> <p><b>*ALL THESE CONDITIONS ARE IN COMPLAINE WITH WHITEWATER RIVER REGION STORM MANAGEMENT PLAN</b></p>		<p>Permit issued in accordance with Section 14.24.060 of the Cathedral City Ordinance Code.</p> <p><b>FEE:</b> <b>\$36.00</b> <b>+ 3% Tech Fee</b></p> <p align="center"><b>100-911-6409</b></p> <p><b>FEE ISSUED IN THE FIELD:</b> <b>\$75.00</b> <b>+3% Tech Fee</b></p>	
SIGNATURE:	BY:	DATE:	RECEIPT NO.:
CC: Code Enforcement      Engineering Division			